



Queensland

Plumbing and Drainage Act 2002

Standard Plumbing and Drainage Regulation 2003

Reprinted as in force on 1 March 2009

Reprint No. 2

This reprint is prepared by
the Office of the Queensland Parliamentary Counsel
Warning—This reprint is not an authorised copy

Information about this reprint

This regulation is reprinted as at 1 March 2009. The reprint—

- shows the law as amended by all amendments that commenced on or before that day (Reprints Act 1992 s 5(c))
- incorporates all necessary consequential amendments, whether of punctuation, numbering or another kind (Reprints Act 1992 s 5(d)).

The reprint includes a reference to the law by which each amendment was made—see list of legislation and list of annotations in endnotes. Also see list of legislation for any uncommenced amendments.

Minor editorial changes allowed under the provisions of the Reprints Act 1992 mentioned in the following list have also been made to—

- use standard punctuation consistent with current drafting practice (s 27)
- reorder definitions consistent with current drafting practice (s 30)
- use aspects of format and printing style consistent with current drafting practice (s 35).

This page is specific to this reprint. See previous reprints for information about earlier changes made under the Reprints Act 1992. A table of reprints is included in the endnotes.

Also see endnotes for information about—

- **when provisions commenced**
- **editorial changes made in earlier reprints.**

Spelling

The spelling of certain words or phrases may be inconsistent with other reprints because of changes made in various editions of the Macquarie Dictionary (for example, in the dictionary, ‘lodgement’ has replaced ‘lodgment’).

Dates shown on reprints

Reprints dated at last amendment All reprints produced on or after 1 July 2002, authorised (that is, hard copy) and unauthorised (that is, electronic), are dated as at the last date of amendment. Previously reprints were dated as at the date of publication. If an authorised reprint is dated earlier than an unauthorised version published before 1 July 2002, it means the legislation was not further amended and the reprint date is the commencement of the last amendment.

If the date of an authorised reprint is the same as the date shown for an unauthorised version previously published, it merely means that the unauthorised version was published before the authorised version. Also, any revised edition of the previously published unauthorised version will have the same date as that version.

Replacement reprint date If the date of an authorised reprint is the same as the date shown on another authorised reprint it means that one is the replacement of the other.



Queensland

Standard Plumbing and Drainage Regulation 2003

Contents

		Page
Part 1	Preliminary	
Division 1	Introduction	
1	Short title	5
2	Commencement	5
Division 2	Status of regulation	
3	Status	5
Division 3	Interpretation	
4	Definitions	6
4A	What is the Queensland Plumbing and Wastewater Code (or QPW code)	6
5	What are the applied provisions and glossary	6
6	Interpretation of applied provisions	6
Part 1A	Prescribed matters for Act	
6B	Criteria for deciding application for compliance permit for greywater use facility in a seweraged area	7
7	Minor work—Act, sch, definition minor work	8
8	Unregulated work—Act, sch, definition unregulated work	8
Part 2	Compliance with particular codes and standards	
8A	Compliance with Plumbing Code of Australia	8
8B	Compliance with QPW code	9
8C	Relationship between PCA and QPW code	9
9	Regulated work and on-site sewerage work	9
10	Minor work and unregulated work	10
11	Limited application of AS/NZS 3500.1:2003	10
12	Limited application of AS/NZS 3500.4:2003	11

Contents

Part 3	Compliance assessment	
Division 1	Preliminary	
13	Application of pt 3.	11
Division 2	Assessing plans	
14	General requirements for plans the subject of a compliance request	11
14A	Additional requirements for plans for regulated work	13
14B	Additional requirements for plans for greywater use facilities in a sewerred area	14
14C	Additional requirements for plans for greywater use facilities not in a sewerred area	15
14D	Additional requirements for plans for on-site sewerage facilities .	17
15	Certificates for plan given by competent person	19
16	Requirement for additional documents for particular plans	20
Division 3	Assessing plumbing and drainage work or on-site sewerage work	
17	Definitions for div 3.	21
18	Request for compliance assessment of regulated work or on-site sewerage work	21
19	Stages for assessment of regulated work	22
19A	Stages for assessment of on-site sewerage work	24
19B	Obligations of responsible person for on-site sewerage work . . .	24
20	Assessment of stages of work by local government.	25
21	Covering plumbing and drainage or on-site sewerage facility . . .	26
22	Testing and commissioning plumbing and drainage.	27
23	General requirements for plans for assessed work	29
23A	Additional requirements for plans for assessed regulated work . .	29
23B	Additional requirements for plans for assessed greywater use facilities in a sewerred area	31
23C	Additional requirements for plans for assessed greywater use facilities not in a sewerred area	31
23D	Additional requirements for plans for assessed on-site sewerage work	32
Division 4	Assessing regulated work or on-site sewerage work in remote areas	
24	Application of div 4	33
25	Meaning of remote area	33
26	Request for compliance assessment of regulated work or on-site sewerage work	34

27	Testing and commissioning plumbing and drainage.	34
28	Plan of completed work	34
29	Notice of compliance	35
Part 4	Product certification	
30	Certified items to be used	36
31	Non-certified items allowed for fire service.	36
32	Unsuitable apparatus, fittings, materials and pipes	38
Part 5	Installations on premises	
Division 1	Supply pipes and drains	
33	Disconnection of supply pipes and sanitary drains	38
34	Building supply pipe to water main standard	39
35	Building sanitary drain to sewerage system standard	40
Division 2	Backflow prevention devices	
36	Installing backflow prevention devices	41
37	Inspection and testing of backflow prevention devices.	41
38	Testable backflow prevention devices.	42
Division 3	Arrestors	
39	Requirements for grease arrestors.	42
40	Connection of appliances and fixtures to grease arrestors	44
Division 4	Other installations for plumbing	
41	Air cooling equipment.	44
42	Engines	45
43	Fire services.	45
44	Hydraulic powered equipment	45
45	Water storage tanks	46
Division 5	Other installations for drainage	
46	Bedpan washers and sanitisers	46
47	Fixtures in basements and cellars	47
48	Floor type urinals	47
49	Flushing bowl and pan room sinks.	48
50	Urinal installations	48
51	Vent pipes to be covered	49
52	Vents in adjoining buildings	49
Part 6	Appointment of inspectors	
53	Qualifications and experience	50

Contents

Part 7	Miscellaneous provisions	
54	Maintenance of existing combined sanitary drains	51
54A	Notice to water service provider about installation of meters	52
55	Evidentiary aids	53
Part 8	Transitional provisions for Plumbing and Drainage Legislation Amendment Regulation (No. 1) 2005	
56	Definition for pt 8	54
57	Existing requests for compliance assessment of plans for regulated work	54
58	Existing requests for compliance assessment of regulated work .	54
59	Plumbing and drainage work	55
Schedule 1	Applied provisions	56
Schedule 1A	References to parts of QPW code	57
Schedule 2	Minor work	58
Schedule 3	Unregulated work	60
Schedule 4	Work for which approved person may give compliance reports	61
Schedule 5	Local governments for remote areas	63
Schedule 6	Dictionary	65
 Endnotes		
1	Index to endnotes	73
2	Date to which amendments incorporated	73
3	Key	73
4	Table of reprints	74
5	List of legislation	74
6	List of annotations	75

Standard Plumbing and Drainage Regulation 2003

[as amended by all amendments that commenced on or before 1 March 2009]

Part 1 Preliminary

Division 1 Introduction

1 Short title

This regulation may be cited as the *Standard Plumbing and Drainage Regulation 2003*.

2 Commencement

This regulation commences on 1 November 2003.

Division 2 Status of regulation

3 Status

- (1) This regulation is the Standard Plumbing and Drainage Regulation under section 145(2) of the Act.
- (2) This regulation can not be changed under a local planning instrument or a local law.
- (3) However, this regulation does not stop a local government making a local planning instrument or a local law dealing with matters outside the scope of this regulation that are related to plumbing and drainage work or on-site sewerage work.

Division 3 Interpretation

4 Definitions

- (1) The dictionary in schedule 6 defines particular words and phrases used in this regulation.
- (2) A word defined in the dictionary as ‘see glossary’ has the meaning given in the glossary.

4A What is the *Queensland Plumbing and Wastewater Code* (or *QPW code*)

- (1) The *Queensland Plumbing and Wastewater Code* (or *QPW code*) is the document called the Queensland Plumbing and Wastewater Code, published by the department.
- (2) In this regulation, a reference to a part of the QPW code is a reference to the part as at the date mentioned for the part in schedule 1A, column 2.

5 What are the *applied provisions* and *glossary*

- (1) The *applied provisions* are the documents listed in schedule 1.
- (2) The *glossary* is the document mentioned in schedule 1, item 1.

6 Interpretation of applied provisions

- (1) This section applies to a word or phrase if—
 - (a) the word or phrase is defined in the glossary; and
 - (b) the word or phrase, or an expression that is in substance equivalent to the word or phrase, is also defined in schedule 6, other than as ‘see glossary’.
- (2) For applying the applied provisions under this regulation, a word or phrase to which this section applies is taken to have, to the greatest practicable extent, the meaning given in schedule 6.

Part 1A Prescribed matters for Act

6B Criteria for deciding application for compliance permit for greywater use facility in a sewered area

The criteria the local government must, under section 85B(3) of the Act, consider in deciding an application for a compliance permit for regulated work for, or that includes, a greywater use facility in a sewered area are—

- (a) the proposed use of the greywater from the greywater use facility; and
- (b) the density of allotments within the relevant locality; and
- (c) the area of land available for dispersal of greywater, after allowing for—
 - (i) setbacks from the boundary of premises at which the facility is proposed to be installed; and
 - (ii) any impervious surfaces; and
- (d) characteristics of the terrain or soil of the premises and of the relevant locality; and

Examples of characteristics of the terrain or soil—

- shape of the surface of the land
 - gradient
 - nature and condition of soil
 - likely surface run-off
 - lateral and vertical drainage and seepage
 - a soil type that is unlikely to be able to assimilate biodegradable organic compounds and pathogenic bacteria
- (e) relevant hydrological and seasonal factors; and

Example—

exposure to sun and wind, rainfall patterns and transpiration from evaporation from vegetation

[s 7]

- (f) whether the application includes the information and documents mentioned in section 14B(3).

7 Minor work—Act, sch, definition *minor work*

- (1) For the Act, schedule, definition *minor work*, minor work is plumbing or drainage work listed in schedule 2.
- (2) For section 87(1) of the Act, notifiable minor work is plumbing or drainage work listed in schedule 2, part 1.

8 Unregulated work—Act, sch, definition *unregulated work*

For the Act, schedule, definition *unregulated work*, unregulated work is plumbing or drainage work listed in schedule 3.

Part 2 Compliance with particular codes and standards

8A Compliance with Plumbing Code of Australia

- (1) Plumbing and drainage work must comply with the PCA, sections A, B, C and G.
- (2) However, plumbing and drainage work is not required to comply with AS/NZS 3500.5:2000 (National plumbing and drainage—domestic installations).
- (3) Plumbing and drainage work complies with the PCA only if the work satisfies the relevant performance requirements under the PCA.
- (4) Compliance with the relevant performance requirements under the PCA can be achieved only by—
 - (a) complying with the relevant deemed-to-satisfy provisions under the PCA; or

- (b) formulating an alternative solution under the PCA that—
 - (i) complies with the performance requirements; and
 - (ii) is shown to be at least equivalent to the relevant deemed-to-satisfy provisions under the PCA; or
- (c) a combination of paragraphs (a) and (b).

8B Compliance with QPW code

- (1) Plumbing and drainage work and on-site sewerage work must comply with the QPW code.
- (2) Plumbing and drainage work or on-site sewerage work complies with the QPW code only if the work satisfies the relevant performance criteria under the QPW code.
- (3) Compliance with the relevant performance criteria can be achieved only by—
 - (a) complying with the relevant acceptable solution under the QPW code; or
 - (b) formulating an alternative solution that—
 - (i) satisfies the performance criteria; and
 - (ii) is shown to be at least equivalent to the relevant acceptable solution under the QPW code; or
 - (c) a combination of paragraphs (a) and (b).

8C Relationship between PCA and QPW code

If the PCA is inconsistent with the QPW code, the QPW code prevails to the extent of the inconsistency.

9 Regulated work and on-site sewerage work

- (1) Subject to sections 11 and 12, regulated work and on-site sewerage work must comply with the applied provisions.

[s 10]

- (2) Despite any provision contained in the applied provisions limiting the application of the applied provisions to certain premises or installations only, under this regulation the applied provisions apply, to the greatest extent possible, to all premises and installations.

10 Minor work and unregulated work

- (1) This section applies to the installation of a plumbing or drainage item if the installation of the item is minor work or unregulated work.
- (2) Subject to section 11, the installation of the item must comply with the applied provisions.

11 Limited application of AS/NZS 3500.1:2003

- (1) This section applies to a local government if it is—
 - (a) carrying out compliance assessment of a plan for regulated work; or
 - (b) assessing regulated work or minor work.
- (2) The local government may apply AS/NZS 3500.1:2003, section 6, for the assessment of fire services for premises only to the following aspects of the plan or work—
 - (a) the method of preventing contamination or pollution of the water supply to the premises;

Example—

providing a testable backflow prevention device upstream of a fire sprinkler system

- (b) the method of jointing, supporting or fixing of the plumbing that is the subject of the plan or work;

Example—

the way a sprinkler head is connected to a pipe in a fire sprinkler system

- (c) the use of the following items in the plumbing—

- (i) a certified item;
- (ii) an item allowed under section 31.

12 Limited application of AS/NZS 3500.4:2003

For applying AS/NZS 3500.4:2003 for regulated work, the reference in clause 1.9.2(b) of the standard to ‘all other buildings’ is taken to be a reference only to buildings classified under BCA as class 1, 2, 3 or 4 buildings.

Part 3 Compliance assessment

Division 1 Preliminary

13 Application of pt 3

This part applies for compliance assessment by a local government of regulated work, on-site sewerage work, and plans for the work.

Division 2 Assessing plans

14 General requirements for plans the subject of a compliance request

- (1) This section imposes requirements for a plan the subject of a compliance request.
- (2) The plan must be drawn to scale and show sufficient dimensions and information to allow the local government to assess the proposed plumbing and drainage or on-site sewerage facility.

[s 14]

- (3) Without limiting subsection (2), the plan must include, or be accompanied by, the documents or information mentioned in—
 - (a) any of the following—
 - (i) for regulated work—section 14A;
 - (ii) for regulated work for, or that includes, a greywater use facility in a sewered area—sections 14A and 14B;
 - (iii) for regulated work for, or that includes, a greywater use facility not in a sewered area—sections 14A and 14C;
 - (iv) for on-site sewerage work—section 14D; and
 - (b) if section 16(1)(b) applies—section 16(2).
- (4) The plan must show—
 - (a) the name of the person who designed the plumbing and drainage or on-site sewerage facility; and
 - (b) for the person mentioned in paragraph (a)—
 - (i) if the person is registered or licensed under a law applying in the State to practise in the aspect of the work—the person’s registration or licence number; or
 - (ii) if the work is on-site sewerage work and subparagraph (i) does not apply—sufficient information about the person’s qualifications and experience to enable the local government to decide whether the person is qualified to design the on-site sewerage facility.
- (5) The information mentioned in subsection (4) must be shown—
 - (a) on each page of the plan; or
 - (b) on a cover sheet at the front of the plan that references each page of the plan.

-
- (6) The person making the request must, if required by the local government, give the local government a reasonable number of copies of the plan.

14A Additional requirements for plans for regulated work

- (1) This section applies, as well as section 14, to a compliance request for regulated work.
- (2) There must be a site plan of the premises on which the regulated work is to be performed showing each of the following—
- (a) the location of proposed or existing buildings or structures on the premises;
 - (b) the ground levels and drainage invert levels, referenced to AHD or appropriately reduced levels, to indicate whether sanitary drains can gravity feed to the connection point for the sewer or on-site sewage treatment plant;
 - (c) the location of each connection point to—
 - (i) a service provider’s water supply or sewerage system; or
 - (ii) an on-site sewage treatment plant; or
 - (iii) a greywater treatment plant;
 - (d) if the work is to be performed on any of the following—the approximate location on the premises of the below ground water supply pipes and sanitary drainage pipes for any plumbing and drainage for the work—
 - (i) a building classified under BCA as a class 1 building, on a lot that is not part of a community titles scheme;
 - (ii) a building classified under BCA as a class 10 building;
 - (e) if the work is to be performed on a building other than a building mentioned in paragraph (d)—the proposed

[s 14B]

location and details of installation for any plumbing and drainage for the work.

- (3) If the regulated work is work to be performed on a building mentioned in subsection (2)(d)—
 - (a) there must be—
 - (i) a floor plan of the building; and
 - (ii) a plan showing the elevations of the building; and
 - (b) the location and details of the building's fixtures must be shown on each of the plans mentioned in paragraph (a).
- (4) If the regulated work is to be performed on a building other than a building mentioned in subsection (2)(d), there must be a floor plan of the building showing the approximate location on the premises of each meter, and details of the specifications of each meter, for measuring the supply of water to any part of the premises.

14B Additional requirements for plans for greywater use facilities in a sewerage area

- (1) This section applies, as well as sections 14 and 14A, to a compliance request for regulated work for, or that includes, a greywater use facility in a sewerage area.
- (2) There must be a site plan of the premises on which the work is to be performed showing each of the following—
 - (a) if the facility includes a greywater application area—
 - (i) the location of the area; and
 - (ii) the distances from the area to the following—
 - (A) the boundary of the premises;
 - (B) proposed or existing buildings or structures on the premises;
 - (C) any impervious surfaces on the premises, including, for example, paths for pedestrians and paved areas;

-
- (b) the connection from the greywater treatment plant or greywater diversion device to sanitary drainage.
- (3) Each of the following must be included—
- (a) a document showing that—
 - (i) the facility’s greywater treatment plant has a chief executive approval; or
 - (ii) the facility’s greywater diversion device has plumbing code authorisation and certification;
 - (b) sufficient information to enable the local government to decide whether any ponding or run-off of the greywater discharged could cause—
 - (i) a danger or health risk to any one; or
Example of a thing that may cause a health risk—
insufficient irrigation area to ensure long-term performance of a greywater use facility
 - (ii) odour that unreasonably interferes, or is likely to unreasonably interfere, with the use or enjoyment of any other premises;
 - (c) if the work is for testing purposes—
 - (i) details of the testing approval for the proposed greywater use facility, including any conditions the chief executive imposes on the approval; and
 - (ii) any other information that the local government requires in relation to the testing;
 - (d) details of the proposed use of the greywater from the greywater use facility.

14C Additional requirements for plans for greywater use facilities not in a sewered area

- (1) This section applies, as well as sections 14 and 14A, to a compliance request for regulated work for, or that includes, a greywater use facility not in a sewered area.

[s 14C]

- (2) There must be a site plan of the premises on which the work is to be performed showing each of the following—
 - (a) the location of the following—
 - (i) if the facility includes a greywater application area—the location of the area;
 - (ii) the proposed greywater treatment plant or greywater diversion device;
 - (iii) any proposed or existing on-site sewage treatment plant;
 - (iv) any proposed or existing on-site sewerage application area, including the layout of drainage for, and the proposed method of applying greywater to, the area;
 - (b) if the facility includes a greywater application area—the distances from the area to the following—
 - (i) the boundary of the premises;
 - (ii) proposed or existing buildings or structures on the premises;
 - (iii) any proposed or existing on-site sewage treatment plant and on-site sewerage application area;
 - (iv) any impervious surfaces on the premises, including, for example, paths for pedestrians and paved areas;
 - (v) each body of water mentioned in paragraph (d);
 - (c) the ground levels, referenced to AHD or appropriately reduced levels, to indicate whether sanitary drains can gravity feed to the connection point for the proposed greywater treatment plant or greywater diversion device;
 - (d) the location of each body of water that may be affected by the greywater from the proposed greywater treatment plant or greywater diversion device;
 - (e) details of the water supply to the premises;

-
- (f) if the work is not for testing purposes—the proposed greywater treatment plant’s type and size.
- (3) Each of the following must be included—
- (a) a site and soil evaluation report, within the meaning of the QPW code, for the premises;
 - (b) if the work is not for testing purposes—
 - (i) a document showing plumbing code authorisation and certification for the proposed greywater diversion device; or
 - (ii) a chief executive approval for the proposed greywater treatment plant;
 - (c) if the work is for testing purposes—
 - (i) details of the testing approval for the proposed greywater use facility, including any conditions the chief executive imposes on the approval; and
 - (ii) any other information that the local government requires in relation to the testing;
 - (d) details of the proposed use of the greywater from the greywater use facility.

14D Additional requirements for plans for on-site sewerage facilities

- (1) This section applies, as well as section 14, to a compliance request for on-site sewerage work.
- (2) There must be a site plan of the premises on which the on-site sewerage work is to be performed showing each of the following—
 - (a) the location of the following—
 - (i) proposed or existing buildings or structures on the premises;
 - (ii) the proposed on-site sewage treatment plant;

[s 14D]

- (iii) the proposed on-site sewerage application area, including the layout of drainage for, and the proposed method of applying effluent to, the area;
 - (b) the distances from the proposed on-site sewerage application area to the following—
 - (i) the boundary of the premises;
 - (ii) proposed or existing buildings or structures on the premises;
 - (iii) any impervious surfaces on the premises, including, for example, paths for pedestrians and paved areas;
 - (iv) each body of water mentioned in paragraph (d);
 - (c) the ground levels, referenced to AHD or appropriately reduced levels, to indicate whether sanitary drains can gravity feed to the connection point for the proposed on-site sewage treatment plant;
 - (d) the location of each body of water that may be affected by the effluent from the proposed on-site sewerage facility;
 - (e) details of the water supply to the premises;
 - (f) if the work is not for testing purposes—the proposed on-site sewage treatment plant's type and size.
- (3) Each of the following must be included—
 - (a) a site and soil evaluation report, within the meaning of the QPW code, for the premises;
 - (b) if the work is not for testing purposes—a document showing plumbing code authorisation and certification, or a chief executive approval, for the proposed on-site sewerage facility;
 - (c) if the work is for testing purposes—
 - (i) details of the testing approval for the proposed on-site sewerage facility, including any conditions the chief executive imposes on the approval; and

- (ii) any other information that the local government requires in relation to the testing.

15 Certificates for plan given by competent person

- (1) This section applies if a plan for regulated work or on-site sewerage work includes a part of the work that the chief executive officer of the local government decides is outside the local government's expertise to assess.
- (2) The local government may accept certification of the plan and associated documents by a competent person.
- (3) The competent person may certify for a plan that plumbing or drainage or an on-site sewerage facility to which certified documentation relates will, if installed or carried out in accordance with the certified documentation, comply with this regulation.
- (4) The name and original signature of the competent person must be on the certified documentation.
- (5) If the certified documentation is prepared on behalf of a corporation or other entity, the name of the corporation or entity must also be on the certified documentation.
- (6) The competent person must personally sign a certificate supporting the certified documentation.
- (7) If the competent person would be required to be licensed for performing the part of the work mentioned in subsection (1), the person's registration or licence number must be on the certificate.
- (8) In this section—
certified documentation, in relation to a plan and associated documents, includes technical details, drawings and specifications for the plan or documents that are given and certified by a competent person.

[s 16]

16 Requirement for additional documents for particular plans

- (1) This section applies if—
 - (a) a person makes a compliance request for a plan; and
 - (b) the plan proposes to comply with—
 - (i) the performance requirements of the applied provisions or the PCA by formulating an alternative solution that is a means of compliance with the applied provisions or the PCA; or
 - (ii) the performance criteria of the QPW code by formulating an alternative solution within the meaning of the code.
- (2) Each of the following must accompany the request—
 - (a) a statement—
 - (i) identifying each performance requirement or performance criteria the solution is intending to satisfy; and
 - (ii) stating how each performance requirement or performance criteria is satisfied by the solution;
 - (b) details of inspection or test results and other documents or information relied on to develop the solution;
 - (c) details of the solution, including, for example, to what extent and specifically how the solution differs from the acceptable solution for the performance requirement or performance criteria;
 - (d) if the solution, or part of the solution, for a performance requirement or performance criteria requires a certified document for the plan—a certificate from the competent person who certified the document.
- (3) In this section—

certified document, for a plan, includes technical details, drawings and specifications for the plan that are given and certified by a competent person.

Division 3 Assessing plumbing and drainage work or on-site sewerage work

17 Definitions for div 3

In this division—

48 hours, for assessing regulated work or on-site sewerage work—

- (a) means a 48 hour period; but
- (b) if a day that is not a business day occurs within the 48 hour period—does not include the day in the calculation of the 48 hour period.

Example—

A local government receives a request for compliance assessment of work on Friday at 10a.m. The following Tuesday at 10a.m. is 48 hours after receiving the request.

responsible person means—

- (a) for regulated work, a person who—
 - (i) is a licensed person for the work; and
 - (ii) performs, directs the performance of, or supervises, the work; or
- (b) for on-site sewerage work that must be assessed—a person who performs, directs the performance of, or supervises, the work.

18 Request for compliance assessment of regulated work or on-site sewerage work

- (1) A person who makes, under section 86(2) of the Act, a request for compliance assessment of regulated work or on-site sewerage work must make the request at least 2 business days before the work starts.

Maximum penalty—20 penalty units.

[s 19]

- (2) If, because of section 83(2) of the Act, a person does not require a compliance permit to perform regulated work, the person must, if required by the local government, give the local government information or documents needed to assess the regulated work, including, for example, the following—
- (a) a site plan showing—
 - (i) the location of proposed or existing buildings or structures; and
 - (ii) the ground levels referenced to AHD to indicate whether sanitary drains can gravity feed to the connection point for the sewer or on-site sewerage facility;
 - (b) a plan of the location of each connection point to—
 - (i) a service provider’s water supply or sewerage system; or
 - (ii) an on-site sewerage facility;
 - (c) the proposed location and details of installation for the plumbing or drainage.
- (3) A person making a request for compliance assessment of on-site sewerage work must give the local government a notice in the approved form of any relevant changes to the premises since the granting of the compliance permit for the work.

Maximum penalty—20 penalty units.

- (4) In this section—
- relevant change*, for premises, means a change to the premises that would have altered the information given when applying, under section 85 of the Act, for the relevant compliance permit.

19 Stages for assessment of regulated work

- (1) Each of the following stages of regulated work is prescribed for section 86(5) of the Act—

- (a) for plumbing or drainage laid under a floor slab or in another area where pipes or fittings will be covered—before the floor slab is laid or the pipes or fittings are covered;
 - (b) for plumbing or drainage that is laid below ground level and external to a building or other structure—before the backfill is placed;
 - (c) for plumbing installed in a building or other structure—before the cladding or lining covering the plumbing is fixed;
 - (d) when the plumbing or drainage work, the subject of the request for compliance assessment, is completed;
 - (e) for a greywater use facility—
 - (i) if the facility includes a greywater application area—after the subsurface or surface irrigation in the area is installed; and
 - (ii) if the greywater is proposed to be used other than in a greywater application area—when the plumbing work associated with each proposed use of the greywater is completed;
 - (f) if the relevant compliance permit imposes a condition requiring an assessment at 1 or more other stages of the work—each stage stated in the condition.
- (2) The responsible person for the work must—
- (a) request an assessment of the work at each of the applicable stages mentioned in subsection (1); and
 - (b) for the stage mentioned subsection (1)(d)—make the request within 7 days after the work is completed; and
 - (c) if the responsible person is not the person who made the request for compliance assessment under section 18(1)—state the responsible person’s name; and

[s 19A]

- (d) before or when the work is assessed, give the local government details in the approved form of the responsible person.

Maximum penalty—20 penalty units.

- (3) However, if the local government requires information or documents under section 18(2), the responsible person may request an assessment of the work only if the information or documents have been provided to the local government.

19A Stages for assessment of on-site sewerage work

Each of the following stages of on-site sewerage work is prescribed for section 86(5) of the Act—

- (a) for a trench or sub-surface irrigation—
 - (i) before filling with backfill; or
 - (ii) after substantially filling with backfill but leaving a cross-sectional area of the trench or sub-surface irrigation not backfilled;
- (b) after all pipes for the relevant on-site sewerage facility are connected, and effluent resulting from sewage generated on the premises can be treated by the on-site sewage treatment plant;
- (c) if the relevant compliance permit imposes a condition requiring an assessment at 1 or more other stages of the work—each stage stated in the condition.

19B Obligations of responsible person for on-site sewerage work

If section 86(6) of the Act does not apply, the responsible person for on-site sewerage work must—

- (a) request the local government to assess the work—
 - (i) at each of the stages for the work prescribed under section 19A; and

-
- (ii) for the stage mentioned in section 19A(b)—within 7 days after the work is completed; and
 - (b) if the responsible person is not the person who made the request for compliance assessment under section 18(1)—give the local government the responsible person's name when first requesting an assessment of the work; and
 - (c) if there is a different responsible person for a stage of work (a *new responsible person*) from the responsible person for the previous stage of work—give the local government the new responsible person's name when requesting an assessment of the new responsible person's stage of work; and
 - (d) before or when the work is assessed, give the local government details in the approved form of the responsible person.

Maximum penalty—20 penalty units.

20 Assessment of stages of work by local government

- (1) This section applies if the local government receives a request for assessment of a particular stage of regulated work or on-site sewerage work.
- (2) An inspector must start assessing the work within 1 hour after—
 - (a) the time agreed between the responsible person for the work and the local government; or
 - (b) if a time is not agreed—48 hours after the local government receives the request.
- (3) The responsible person must give the inspector the help the inspector reasonably requires to inspect the work.
- (4) If, in deciding the request, the inspector gives the responsible person written notice of the action required to make the relevant plumbing or drainage or on-site sewerage facility

[s 21]

comply with this regulation, the person must, within 2 business days after receiving the notice—

- (a) comply with the notice; and
- (b) make a request for assessment of the work that is the subject of the notice.

Maximum penalty for subsection (4)—20 penalty units.

21 Covering plumbing and drainage or on-site sewerage facility

(1) A responsible person for regulated work or on-site sewerage work must not cover, or allow another person to cover, the relevant plumbing or drainage or on-site sewerage facility unless an inspector has—

- (a) assessed the work and decided it complies with this regulation; or
- (b) allowed the plumbing or drainage or on-site sewerage facility to be covered; or
- (c) for on-site sewerage work—accepted from an approved person a notice of compliance for the work given under section 86(6) of the Act.

Maximum penalty—20 penalty units.

(2) If the person fails to comply with subsection (1), the inspector may—

- (a) require the person to verify the work complies with this regulation; or
- (b) give the person written notice of the action required to enable the inspector to assess whether the work complies.

(3) However, the person may cover the plumbing or drainage or on-site sewerage facility if the inspector fails to start assessing the work within 1 hour after—

- (a) the agreed time for the assessment; or

-
- (b) if a time is not agreed—48 hours after the local government receives the request.
 - (4) If the person covers the plumbing or drainage or on-site sewerage facility under subsection (3), the inspector may require the person to verify in the approved form that the work complies with this regulation.
 - (5) A person must provide verification required of the person under subsection (2)(a) or (4).

Maximum penalty—10 penalty units.

22 Testing and commissioning plumbing and drainage

- (1) If an inspector requires plumbing or drainage, the subject of regulated work, to be tested or commissioned—
 - (a) the inspector must observe the testing or commissioning of the plumbing or drainage; or
 - (b) if the inspector allows, an approved person must test, commission or observe the testing or commissioning of the plumbing or drainage.
- (2) An inspector may allow an approved person to test or commission the plumbing and drainage only if the work is work mentioned in schedule 4.
- (3) An approved person must test or commission the plumbing or drainage—
 - (a) for plumbing or drainage installed to comply with a deemed-to-satisfy provision under PCA—in accordance with the relevant applied provision mentioned in schedule 4, part 1; or
 - (b) for plumbing or drainage installed to comply with an alternative solution—to ensure the plumbing or drainage complies with the relevant performance requirements under PCA, or other requirements, mentioned in schedule 4, part 2.
- (4) If subsection (2) applies, the approved person must, within 5 business days after testing or commissioning the plumbing or

[s 22]

drainage, give the responsible person a report about the testing or commissioning (a *compliance report*) complying with subsection (5).

Maximum penalty—10 penalty units.

- (5) The compliance report must—
- (a) state—
 - (i) that the approved person has tested or commissioned the plumbing or drainage in accordance with the applied provisions; or
 - (ii) that the approved person has observed the testing or commissioning of the plumbing or drainage and that the plumbing or drainage was tested or commissioned in accordance with the applied provisions; and
 - (b) state the extent to which the approved person has relied on tests, specifications, rules, standards, codes of practice or other publications; and
 - (c) state whether the plumbing or drainage complies with the applied provisions; and
 - (d) if the plumbing or drainage does not comply with the applied provisions, state the extent to which the plumbing or drainage does not comply; and
 - (e) be signed by the approved person.
- (6) The responsible person for the regulated work must give the local government the compliance report—
- (a) within 10 business days after the testing or commissioning of the the plumbing or drainage; or
 - (b) if the local government allows—at a time more than 10 business days after the testing or commissioning.

Maximum penalty—10 penalty units.

- (7) In this section—
approved person means—

- (a) the person who performed the regulated work; or
- (b) another person who—
 - (i) in the opinion of the local government, is competent to test or commission the plumbing or drainage; and
 - (ii) if required under the Act or another Act to be registered or licensed to practise in the aspect of the work, is registered or licensed.

23 General requirements for plans for assessed work

- (1) This section applies if, under section 86(7) of the Act, the local government asks a person making a request for compliance assessment of regulated work or on-site sewerage work to supply a plan for the assessed work.
- (2) The plan must contain enough information about the work to enable the local government to keep an accurate record of the plumbing or drainage or the relevant on-site sewerage facility that is the subject of the work.

23A Additional requirements for plans for assessed regulated work

- (1) This section applies, as well as section 23, to a request for a plan for assessed regulated work.
- (2) If the work is in relation to a building classified under BCA as a class 1 building on a lot that is part of a community titles scheme or a class 2 to 9 building, the plan must be drawn to scale and show—
 - (a) the location, including dimensions, of each connection point to—
 - (i) the service provider’s water supply or sewerage system; or
 - (ii) the on-site sewerage facility; and
 - (b) the location on the premises of the following items—

[s 23A]

- (i) all fixtures, water supply pipes, sanitary drains and water meters;
 - (ii) each connection point to the service provider's water supply or sewerage system, or to the on-site sewerage facility;
 - (iii) each access point for cleaning and maintaining the plumbing and drainage;
 - (iv) each reflux valve installed in the drainage;
 - (v) any installed testable backflow prevention devices.
- (3) If the work is in relation to a building classified under BCA as a class 1 building or class 10 building, other than a class 1 building mentioned in subsection (2), the plan must be drawn approximately to scale and show—
- (a) the location, including dimensions, of each connection point to—
 - (i) the service provider's water supply or sewerage system; or
 - (ii) the on-site sewerage facility; and
 - (b) the approximate location on the premises of the following items—
 - (i) all fixtures, water supply pipes and sanitary drains;
 - (ii) each connection point to the service provider's water supply or sewerage system, or to the on-site sewerage facility;
 - (iii) each access point for cleaning and maintaining the plumbing and drainage;
 - (iv) each reflux valve installed in the drainage;
 - (v) any installed testable backflow prevention devices.

23B Additional requirements for plans for assessed greywater use facilities in a sewerred area

- (1) This section applies, as well as sections 23 and 23A, to a request for regulated work for, or that includes, a greywater use facility in a sewerred area.
- (2) The plan must be drawn approximately to scale and show the following if the greywater use facility includes a greywater application area—
 - (a) the location of the area;
 - (b) the distances from the area to the following—
 - (i) the boundary of the premises;
 - (ii) proposed or existing buildings or structures on the premises.
- (3) The plan must include details of the proposed use of the greywater from the greywater use facility.

23C Additional requirements for plans for assessed greywater use facilities not in a sewerred area

- (1) This section applies, as well as sections 23 and 23A, to a request for regulated work for, or that includes, a greywater use facility not in a sewerred area.
- (2) The plan must be drawn approximately to scale and show the following—
 - (a) the location of the following—
 - (i) if the greywater use facility includes a greywater application area—the area;
 - (ii) any proposed or existing on-site sewage treatment plant;
 - (iii) any proposed or existing on-site sewerage application area, including the layout of drainage for, and the proposed method of applying greywater to, the area;

[s 23D]

- (b) if the facility includes a greywater application area—the distances from the area to the following—
 - (i) the boundary of the premises;
 - (ii) proposed or existing buildings or structures on the premises;
 - (iii) any proposed or existing on-site sewerage application area.
- (3) The plan must include details of the proposed use of the greywater from the greywater use facility.

23D Additional requirements for plans for assessed on-site sewerage work

- (1) This section applies, as well as section 23, to a request for a plan for assessed on-site sewerage work.
- (2) The plan must be drawn approximately to scale and show the following—
 - (a) the location of proposed or existing buildings or structures on the premises on which the on-site sewerage facility has been installed;
 - (b) the location of the on-site sewage treatment plant;
 - (c) the location of the on-site sewerage application area;
 - (d) the distances from the on-site sewerage application area to the following—
 - (i) the boundary of the premises;
 - (ii) buildings or structures on the premises;
 - (e) the location of each body of water that may be affected by effluent from the on-site sewerage facility;
 - (f) the distances between the on-site sewerage facility and each body of water mentioned in paragraph (e).

Division 4 **Assessing regulated work or on-site sewerage work in remote areas**

24 **Application of div 4**

This division applies, under section 86A of the Act, for the assessment of regulated work or on-site sewerage work in a remote area.

25 **Meaning of *remote area***

(1) A ***remote area*** means an area of land included in a local government's area—

- (a) all of which is outside a declared water or sewerage service area under the *Water Act 2000*; and
- (b) none of which is within a populated place; and
- (c) all of which is—
 - (i) more than 80km from the nearest office of the local government; or
 - (ii) reasonably difficult to access.

Examples for subparagraph (ii)—

- 1 an island without a regular water vehicle service from the mainland
- 2 weather conditions or other circumstances that make usual access to the land difficult or dangerous

(2) However, a ***remote area*** does not include land if—

- (a) there is an activity on the land, including, for example, mining or another industrial use; and
- (b) it is probable the nature of the activity will increase the likelihood and severity of harm to the public if the plumbing and drainage or on-site sewerage facility on the land does not operate effectively.

[s 26]

(3) In this section—

local government means a local government listed in schedule 5.

populated place means a place with an approved name under the *Place Names Act 1994* and designated in the Gazetteer of Place Names under that Act as a populated place.

26 Request for compliance assessment of regulated work or on-site sewerage work

A person who makes, under section 86A(2) of the Act, a request for compliance assessment of regulated work or on-site sewerage work, must make the request at least 2 business days before the work starts.

Maximum penalty—20 penalty units.

27 Testing and commissioning plumbing and drainage

If a local government decides to test or commission plumbing or drainage, the subject of regulated work carried out in a remote area, section 22 applies to the testing or commissioning of the plumbing or drainage as if the plumbing or drainage were the subject of regulated work carried out in an area other than a remote area.

28 Plan of completed work

- (1) This section applies if, under section 86A(3)(b) of the Act, the local government asks a person making a request for compliance assessment of regulated work or on-site sewerage work to supply a plan of the completed work.
- (2) The plan must comply with the requirements for a plan of assessed work—
 - (a) for regulated work—under sections 23 and 23A; or
 - (b) for regulated work for, or that includes, a greywater use facility in a sewerred area—under sections 23 to 23B; or

- (c) for regulated work for, or that includes, a greywater use facility not in a sewerred area—under sections 23, 23A and 23C; or
- (d) for on-site sewerage work—under sections 23 and 23D.

29 Notice of compliance

- (1) A notice given under section 86A(3)(a) of the Act must be given by—
 - (a) the person who performs the work; or
 - (b) if the local government decides to accept notice from another person—an approved person.
- (2) The notice must be—
 - (a) in the approved form; and
 - (b) given within 10 business days after the work is completed.
- (3) If the local government decides to accept notice from an approved person, the local government must advise the person who performs the work of its decision.
- (4) In this section—

approved person means a person who—

 - (a) in the opinion of the local government, is competent to verify the work complies with this regulation; and
 - (b) if required by law to be registered or licensed under a law applying in the State to practise in the aspect of the work, is registered or licensed.

[s 30]

Part 4 Product certification

30 Certified items to be used

- (1) A person must not install or use a plumbing or drainage item in plumbing or drainage if the item is not a certified item.
Maximum penalty—20 penalty units.
- (2) A person commits an offence under subsection (1) for each plumbing or drainage item used or installed that is not a certified item.
- (3) However, subsection (1) does not apply to stop the continued use of a plumbing or drainage item—
 - (a) in plumbing or drainage installed before the commencement of this section; or
 - (b) if the local government is satisfied that use of the item is necessary for maintaining the plumbing or drainage in its original form and approves the continued use of the item.
- (4) For approving the continued use of a plumbing or drainage item under subsection (3)(b), the local government may require a person to have the item tested at the person's cost within a stated reasonable time and at a stated reasonable place.
- (5) This section is subject to section 31.

31 Non-certified items allowed for fire service

- (1) A person may install or use a plumbing or drainage item that is not a certified item if the item is—
 - (a) part of a fire service that is installed and used solely for fire fighting; and
 - (b) if the fire service is connected to a water service provider's infrastructure—installed downstream of a testable backflow prevention device; and

-
- (c) tested in accordance with a specified test method endorsed by a JAS-ANZ certification body; and
 - (d) listed for the specific use in a fire service by—
 - (i) a nationally or internationally recognised body for testing and approving fire services; or

Examples—

- 1 Scientific Services Laboratory
- 2 Underwriters Laboratories
- 3 Factory Mutual
- 4 Loss Prevention Council

- (ii) a JAS-ANZ certification body; and

Example—

A pipe listed for use in a fire sprinkler system is not suitable for use in a fire hydrant installation unless the pipe is also listed for that specific use.

- (e) marked in accordance with a scheme endorsed by a JAS-ANZ certification body.

Maximum penalty—20 penalty units.

- (2) A testable backflow prevention device mentioned in subsection (1)(b) is not required to be a certified item if it is tested in accordance with the QPW code, part 6.
- (3) In this section—

JAS-ANZ means the Joint Accreditation System of Australia and New Zealand that was declared under the *Joint Accreditation System of Australia and New Zealand (Privileges and Immunities) Regulations 1998* (Cwlth) to be an international organisation to which the *International Organisations (Privileges and Immunities) Act 1963* (Cwlth) applies.

JAS-ANZ certification body means a certification body registered by JAS-ANZ for providing product certification systems.

[s 32]

testable backflow prevention device includes a testable single check valve.

32 Unsuitable apparatus, fittings, materials and pipes

If an inspector is satisfied that a plumbing or drainage item is unsuitable for use in particular circumstances, the local government may—

- (a) require that the item is not installed or used in the circumstances; and
- (b) approve the installation or use of—
 - (i) the item, but with a protective coating, lining or wrapping for the item; or
 - (i) another plumbing or drainage item.

Example of an unsuitable plumbing or drainage item—

a polyethylene pipe installed below ground level if there are petrochemicals in the ground

Part 5 Installations on premises

Division 1 Supply pipes and drains

33 Disconnection of supply pipes and sanitary drains

If a supply pipe or sanitary drain is no longer needed because an installation on premises is dismantled, the owner of the premises must take all reasonable steps to ensure that—

- (a) all apparatus and fittings are disconnected from the supply pipe or sanitary drain; and
- (b) each opening to the supply pipe or sanitary drain is sealed with a plug.

Maximum penalty—20 penalty units.

Editor's note—

See the *Water Supply (Safety and Reliability) Act 2008*, section 191 (Connecting to or disconnecting from service provider's infrastructure without approval) for the requirement that a person must not, without the written consent of a service provider, disconnect from the service provider's infrastructure.

34 Building supply pipe to water main standard

- (1) This section applies if a supply pipe for premises or a premises group is to be built and the local government believes on reasonable grounds that an ordinary supply pipe can not give an efficient water supply for the premises or premises group.

Example—

An ordinary supply pipe may not give an efficient water supply to the campus of a tertiary educational institution that contains various detached buildings requiring a water supply.

- (2) For a supply pipe for premises, the local government may require—
 - (a) part or all of the supply pipe (the *premises main*) to be built to the standard of a water main; and
 - (b) the premises main to supply directly each separately occupied part of the premises; and
 - (c) the premises main to supply directly each fire service within the premises.
- (3) For a supply pipe for a premises group, the local government may require—
 - (a) a part of the supply pipe (the *premises group main*) to be built, in the way and to the extent directed by the local government, to the standard of a water main; and
 - (b) each separately occupied part of the premises group to be served directly by a supply pipe connected to the premises group main; and

[s 35]

- (c) each separately occupied part of the premises group that is to have a fire service to be served directly by a fire service connected to the premises group main.
- (4) To remove any doubt, it is declared that—
 - (a) a private main is not the property of the local government or another service provider; and
 - (b) the local government or other service provider is not responsible for the maintenance of the private main downstream from the connection point for the private main.
- (5) A supply pipe or fire service connected as required under subsection (2)(b) or (c) or (3)(b) or (c) must be fitted with an isolating valve.
- (6) In this section—
 - premises group* includes a proposed premises group.
 - private main* means the premises main or the premises group main.

35 Building sanitary drain to sewerage system standard

- (1) This section applies if sanitary drainage for premises or a premises group is to be built and the local government believes on reasonable grounds that drainage alone can not give efficient drainage for the premises.

Example—

Drainage alone may not give an efficient drainage to the campus of a tertiary educational institution that contains various detached buildings required to be connected to drainage.

- (2) For sanitary drainage for premises, the local government may require the building of a sewer for the premises (the *premises sewer*) that is to the standard of a sewer forming part of the local government's or another service provider's sewerage system.
- (3) For sanitary drainage for a premises group, the local government may require a sewer for the premises group (the

premises group sewer) be built to the standard of a sewer forming part of the local government's or another service provider's sewerage system.

- (4) To remove any doubt, it is declared that—
- (a) a private sewer is not the property of the local government or another service provider; and
 - (b) the local government or other service provider is not responsible for the maintenance of the private sewer downstream from the connection point for the private sewer.
- (5) In this section—

private sewer means the premises sewer or the premises group sewer.

Division 2 Backflow prevention devices

36 Installing backflow prevention devices

- (1) An appropriate backflow prevention device must be installed on premises if pollution of the water supply on the premises or the water service provider's water service to the premises has been, or could be, caused by the plumbing on the premises.
- (2) In this section—

appropriate backflow prevention device means a backflow prevention device that is specified for the particular circumstances under the applied provisions.

37 Inspection and testing of backflow prevention devices

A person who, under section 117(2)(c) of the Act, inspects or tests a backflow prevention device must, within 10 business days after inspecting or testing the device, give the local government written results of the inspection or test.

Maximum penalty—10 penalty units.

[s 38]

38 Testable backflow prevention devices

- (1) A local government must implement and maintain a program for its local government area for the registration, maintenance and testing of testable backflow prevention devices installed in the area.
- (2) The local government, or an entity authorised by the local government, must keep a register of the testable backflow prevention devices.
- (3) An owner of an installed testable backflow prevention device must—
 - (a) register the device with the local government or entity; and
 - (b) at least once each year, have the device inspected or tested by a person who is licensed to do the work.

Maximum penalty—20 penalty units.

- (4) A person who inspects or tests a testable backflow prevention device must, within 10 business days after inspecting or testing the device, give the local government written results of the inspection or test in the approved form.

Maximum penalty—10 penalty units.

Division 3 Arrestors

39 Requirements for grease arrestors

- (1) A grease arrestor on premises must—
 - (a) be installed in an accessible position, preferably outside a building, and as close as practicable to the appliance or fixture the arrestor serves; and
 - (b) have a childproof cover or, if it is in an area subject to motor vehicle traffic, a suitable heavy duty cover; and
 - (c) if the arrestor is installed inside a building and in an area used for food preparation—

- (i) have a cover that is airtight; and
 - (ii) have its arrestor chamber fitted with a vent of a size of at least 50mm; and
 - (d) have a capacity below the invert of the outlet of at least twice the total capacity of the appliances and fixtures connected to it or, if the local government requires a larger capacity for the arrestor, the larger capacity; and
 - (e) have inlet and outlet ventilation of the standard for sanitary plumbing.
- (2) The following must be fitted with a trap—
- (a) an appliance or fixture discharging to the arrestor;
 - (b) the arrestor outlet.
- (3) The size of the arrestor outlet must be at least 100mm.
- (4) The clean-out point for the arrestor must be accessible.
- (5) The distance from the top of the arrestor to the outlet invert must be at least half the depth of the arrestor below the outlet invert.
- (6) The outlet invert level of the arrestor must be at least 50mm below the inlet invert level.
- (7) Any outlet pipe from the arrestor must—
- (a) be of a diameter approved by the local government; and
 - (b) have a cross-sectional area of at least the combined cross-sectional areas of the incoming waste pipe.
- (8) The design and location of the ventilation for the arrestor must be as approved by the local government.
- (9) In approving the design and location of the arrestor's ventilation under subsection (8), the local government must have regard to the arrestor's design and the location of trap water seals in the arrestor.

[s 40]

40 Connection of appliances and fixtures to grease arrestors

- (1) If an appliance or fixture is connected to a grease arrestor in a way that complies with this section, the appliance or fixture is not required to be separately vented in the way required under the applied provisions.
- (2) The connecting pipe must be as short and direct as possible but, if its size is 50mm or less, it must not be longer than 2.5m.
- (3) If the appliance or fixture is for collecting greasy discharges from floor areas, it must be connected to the inlet pipe of the arrestor in 1 of the following ways—
 - (a) separately and uninterrupted by a trap water seal or air gap;
 - (b) in combination through a 100mm or larger pipe with an upstream vent.

Division 4 Other installations for plumbing

41 Air cooling equipment

- (1) Air cooling equipment may be connected to a supply pipe only if—
 - (a) the local government has approved the connection; and
 - (b) the equipment is fitted with the means of recovering and recycling water or with a backflow prevention device that is suitable for the purpose.
- (2) Subsection (1) does not apply to air cooling equipment if—
 - (a) the air cooling equipment is in the form of a domestic evaporative air conditioner; and
 - (b) the local government has approved the connection and use of the equipment.

-
- (3) The local government may give an approval under subsection (2) only if the local government is satisfied that it is reasonable in the circumstances to allow the equipment's use.

42 Engines

Water must not be supplied to an engine directly from a supply pipe.

43 Fire services

A fire service must not be extended other than for a fire service purpose.

44 Hydraulic powered equipment

- (1) Hydraulic powered equipment may be connected to a supply pipe only if—
- (a) the local government has approved the connection; and
 - (b) the equipment is fitted with the means of recovering and recycling water or with a backflow prevention device that is suitable for the purpose.
- (2) Subsection (1) does not apply to hydraulic powered equipment if—
- (a) the hydraulic powered equipment is in the form of a domestic water lift; and
 - (b) the local government has approved the connection and use, on premises occupied by a disabled person, of the equipment.
- (3) The local government may give an approval under subsection (2) only if the local government is satisfied there is no other practical or economic way of giving mobility to the disabled person.
- (4) In this section—

hydraulic powered equipment means plant, apparatus or machinery using water supply for hydraulic power.

[s 45]

45 Water storage tanks

- (1) A pipe carrying water supplied by the local government or other service provider must not, without a local government's written approval—
 - (a) be connected to a water storage tank used to store water obtained from another source; or
 - (b) be discharged into a water storage tank used to store water obtained from another source.
- (2) If the local government gives an approval under subsection (1), a backflow prevention device must be installed on the pipe carrying the water supplied by the local government.

Division 5 Other installations for drainage

46 Bedpan washers and sanitisers

- (1) A pressurised steam bedpan washer installed and used on premises must, to the extent that it is reasonably practicable, comply with this section.
- (2) The washer must—
 - (a) be directly connected to a drain or soil stack; and
 - (b) have its own steam relief vent or another way of relieving pressure in the washer to prevent traps blowing if the pressure rises above 0.35kPa.
- (3) Soil stacks, soil pipe vents and steam relief vents for the washer must not be made from thermoplastic pipe.
- (4) A steam relief vent for the washer must have a size of at least 40mm and end above the roof of the building it is in.
- (5) A branch steam relief vent for the washer must be graded downwards at its point of connection to the main steam relief vent for the washer to give an invert fall equal to half the branch steam relief vent's diameter.
- (6) The main steam relief vent for the washer must discharge condensate to a sanitary drain by—

- (a) connection to a disconnecter gully; or
 - (b) if there is 1 other bedpan washer, or if there are 2 or more other bedpan washers, on the premises and all are connected—the interconnection of the base of the main steam relief vent to the fixture trap riser of the lower or lowest of all the connected bedpan washers.
- (7) The points of connection to the main steam relief vent must be at least 300mm above the washers if—
- (a) there are 2 or more bedpan washers on the premises; and
 - (b) the steam relief vents from the washers are interconnected.

47 Fixtures in basements and cellars

- (1) A water closet pan, urinal or another fixture must not be installed in a part of premises below the level of the sewer or on-site sewerage facility for the premises unless the local government's approval has been obtained for the installation.
- (2) The local government may give an approval under subsection (1) only if it is satisfied on reasonable grounds that there is adequate provision for lifting waste water to the sewer or on-site sewerage facility and preventing sewage flowing back into the room.

48 Floor type urinals

- (1) A floor type urinal must not be installed if the urinal, or the way the urinal is installed, does not comply with this section.
- (2) If the floor near the urinal is exposed to rainwater, sand, mud or anything else that may enter the urinal channel, the urinal must have a step in front of the channel.
- (3) The step must—
 - (a) be at least 400mm wide, measured from the inside face of the urinal channel; and

[s 49]

- (b) have a tread of an impervious material graded to the urinal channel; and
 - (c) have a rise of at least 100mm but not more than 150mm.
- (4) The level of the floor or tread must be at least 25mm above the top of the urinal channel and the joint between the step and the urinal channel must be sealed with a flexible caulking compound.

49 Flushing bowl and pan room sinks

- (1) A flushing bowl or pan room sink must not be installed if the bowl or sink, or the way the bowl or sink is installed, does not comply with this section.
- (2) A flushing bowl must—
 - (a) have an integral trap of at least 80mm and a flushing apparatus; and
 - (b) be directly connected to a sanitary drain or soil stack.
- (3) The waste pipe from the trap of a pan room sink may be connected to a vertical soil pipe from a flushing bowl trap only if the waste pipe is vented by a pipe of at least 50mm connected between the sink and the flushing bowl.
- (4) If there are 2 pan room sinks installed, and the waste pipes from the traps of the 2 sinks are connected to the vertical soil pipe from a flushing bowl trap, the vent must be connected between the sink outlets.
- (5) A pan room sink must connect directly to a drain or soil stack through traps and waste pipes of a size of at least 50mm.

50 Urinal installations

- (1) A prefabricated urinal must not be installed if the urinal, or the way the urinal is installed, does not comply with this section.

-
- (2) The floor of the compartment or room containing the urinal must drain to a floor waste gully or the urinal channel, or directly through a trap to a sanitary drain or soil stack.
 - (3) If the urinal is a slab urinal, it must—
 - (a) have a continuous channel at least 50mm deep and 150mm wide; and
 - (b) be graded at least 1:100 to the outlets.
 - (4) If the urinal is a floor type urinal, the height of the slab above the top of the channel must be at least 960mm.
 - (5) Edges and corners of urinal fixtures must be smoothly rounded to a radius of at least 13mm and the ends of the slab must return at least 250mm.

51 Vent pipes to be covered

- (1) A vent pipe must have a cowl over the end of the vent pipe that has the same effective ventilation capacity as the vent pipe.
- (2) If the pipe is connected to an on-site sewerage facility, the cowl must be a mosquito proof type of cowl.

52 Vents in adjoining buildings

- (1) This section applies if a building (the *new building*) is erected next to a building of a lower height (the *old building*) in a way requiring a change to the vents of the old building to comply with requirements about vents included in the applied provisions.
- (2) The local government may, by written notice given to the owner of the new building and the owner of the old building, require that—
 - (a) the new building's owner pay the reasonable cost of changing the vents on the old building; and
 - (b) the old building's owner change the vents.

-
- (3) On and from 1 November 2006, if the individual is to assess on-site sewerage facilities, the individual must have the following—
- (a) the qualifications, skills and experience that, in the opinion of the local government appointing the individual, gives the individual the necessary competence for inspecting and approving on-site sewerage facilities; and
- (b) either—
- (i) a drainers licence with an endorsement for on-site sewerage facility maintenance; or
- Editor's note—*
- See the *Plumbing and Drainage Regulation 2003*, schedule 3 (Qualifications, practical experience and scope of work for endorsements), item 3.
- (ii) a restricted licence for a drainer—on-site sewerage facility; or
- Editor's note—*
- See the *Plumbing and Drainage Regulation 2003*, schedule 2 (Qualifications, practical experience and scope of work for restricted licences), item 7.
- (iii) a qualification that the board decides, or has decided, gives the individual the necessary competence for inspecting and approving on-site sewerage facilities.

Part 7 Miscellaneous provisions

54 Maintenance of existing combined sanitary drains

- (1) This section applies if—
- (a) 2 or more premises in a local government's seweraged area are served by an existing combined sanitary drain; and

[s 54A]

- (b) the drain is obstructed, in disrepair or damaged because of defective materials, breakages or tree root intrusion; and
 - (c) the owners of the premises can not agree on suitable and fair arrangements for removing the obstruction or repairing or rebuilding the drain.
- (2) However, this section does not apply to a sanitary drain if the premises that the sanitary drain serves—
- (a) is included in a community titles scheme under the *Body Corporate and Community Management Act 1997*; or
 - (b) forms part of a building unit plan or group title plan under the *Building Units and Group Titles Act 1980*.
- (3) The local government may—
- (a) perform the work; and
 - (b) fairly apportion the reasonable overall cost between or among the owners; and
 - (c) recover, as a debt from each owner, the owner's share of the costs.

54A Notice to water service provider about installation of meters

- (1) This section applies if plumbing work involving the installation of water meters is performed—
- (a) on a building other than a building mentioned in section 14A(2)(d); and
 - (b) after 1 January 2008 in relation to a compliance request made after 31 December 2007.
- (2) The responsible person for the work must, at least 2 business days before the cladding or lining covering the plumbing work is fixed, give the water service provider for the area in which the work is being performed written notice that the water meters are proposed to be installed.

Maximum penalty—20 penalty units.

-
- (3) In this section—
- responsible person*, for work, means the person who—
- (a) is a licensed person for the work; and
 - (b) performs, directs the performance of, or supervises, the work.

55 Evidentiary aids

- (1) This section applies to a proceeding under, or in relation to, this regulation.
- (2) A certificate purporting to be signed by the chief executive stating any of the following matters is evidence of the matter—
 - (a) a stated document is a copy of, or an extract from or part of—
 - (i) the PCA; or
 - (ii) the QPW code;
 - (b) an edition of the PCA was the current edition of the PCA at a stated time or during a stated period;
 - (c) a particular version of the QPW code was in force at a stated time or during a stated period;
 - (d) a particular part of the QPW code was in force at a stated time or during a stated period.
- (3) In a proceeding under section 54(3) by a local government to recover costs from owners of premises, a certificate by the chief executive officer of the local government stating any of the following matters is evidence of the matter—
 - (a) a matter mentioned in section 54(1);
 - (b) that stated work has been performed under section 54(3)(b);
 - (c) that a stated apportionment is a fair apportionment of the cost among the owners.

Part 8

Transitional provisions for Plumbing and Drainage Legislation Amendment Regulation (No. 1) 2005

56 Definition for pt 8

In this section—

commencement means the day this section commences.

unamended regulation means this regulation as in force immediately before the commencement.

57 Existing requests for compliance assessment of plans for regulated work

- (1) This section applies if—
 - (a) before the commencement, a request for compliance assessment of a plan for regulated work was made under section 85(1) of the Act as in force immediately before the commencement; and
 - (b) immediately before the commencement, the request had not been decided.
- (2) The unamended regulation applies to—
 - (a) deciding the request; and
 - (b) if a compliance permit for the work is given—assessing the plan.

58 Existing requests for compliance assessment of regulated work

- (1) This section applies if—
 - (a) before the commencement, a request for compliance assessment of regulated work was made under section 86(1) or 86A(2) of the Act as in force immediately before the commencement; and

- (b) immediately before the commencement, the work had not been assessed.
- (2) The unamended regulation applies to assessing the work.

59 Plumbing and drainage work

- (1) This section applies to the following—
 - (a) regulated work for which a compliance permit has been given before the commencement;
 - (b) minor work or unregulated work, started but not finished before the commencement.
- (2) The unamended regulation applies to the work.

Schedule 1 Applied provisions

section 5

- 1 AS/NZS 3500.0:2003 (Plumbing and drainage—Glossary of terms)
- 2 AS/NZS 3500.1:2003 (Plumbing and drainage—Water services)
- 3 AS/NZS 3500.2:2003 (Plumbing and drainage—Sanitary plumbing and drainage)
- 4 AS/NZS 3500.4:2003 (Plumbing and drainage—Heated water services)
- 5 AS/NZS 1546.1:1998 (On-site domestic wastewater treatment units—Septic tanks)
- 6 AS/NZS 1546.3:2001 (On-site domestic wastewater treatment units—Aerated wastewater treatment systems)
- 7 AS/NZS 1547:2000 (On-site domestic wastewater management)

**Schedule 1A References to parts of QPW
code**

section 4A

Parts of QPW code	Date published
1—Onsite Wastewater Management Systems	3 February 2009
2—Greywater Use Facilities	3 February 2009
3—Land Application Systems	3 February 2009
4—Water Meters for New Premises	3 February 2009
5—Chief Executive Approvals	3 February 2009
6—Non certified testable backflow prevention devices for fire service	3 February 2009
7—New and replacement electric hot water systems	3 February 2009
8—Water conservation for class 1 and class 2 buildings	3 February 2009

Schedule 2 Minor work

section 7

Part 1 Notifiable minor work

- emergency work
- repairing or replacing a plumbing or drainage pipe that is broken or damaged, but not if the work involves repairing a pipe or drain at a connection point or replacing more than 6m of a pipe or 3m of a drain
- other work of a minor nature related to, and reasonably necessary for, repairing plumbing or drainage
- work necessary for replacing a tempering valve, water heater, cistern, pump or water meter
- work necessary for maintaining, repairing or replacing a backflow prevention device or thermostatic mixing valve
- work temporarily installed downstream of a backflow prevention device if the work remains in place for less than 4 weeks
- repairing or replacing a greywater treatment plant or greywater diversion device

Part 2 Other minor work

- work necessary for maintaining, repairing or replacing a fitting or fixture
- work necessary for maintaining or repairing an apparatus other than a backflow prevention device or thermostatic mixing valve

- work necessary for replacing apparatus other than a backflow prevention device, thermostatic mixing valve, tempering valve, water heater, cistern, pump or water meter
- work necessary for maintaining, repairing or replacing fire hydrants or fire hose reels
- unblocking a pipe that is sanitary plumbing or sanitary drainage

Schedule 3 Unregulated work

section 8

For sanitary plumbing and sanitary drainage

- cleaning or maintaining ground level grates to traps on sanitary drains
- replacing caps to ground level inspection openings on sanitary drains
- maintaining an above or below ground irrigation system for the disposal of effluent from an on-site sewerage facility

For water plumbing

- installing or maintaining an irrigation or lawn watering system downstream from an isolating valve, tap or backflow prevention device on the supply pipe for the irrigation or lawn watering system
- replacing a jumper valve or washer in a tap
- changing a shower head
- replacing, in a water closet (WC) cistern, a drop valve washer, float valve washer or suction cup rubber

**Schedule 4 Work for which approved
person may give compliance
reports**

section 22

**Part 1 Complying with
deemed-to-satisfy provisions
under PCA**

- 1 testing or commissioning of a water service in accordance with AS/NZS 3500.1:2003 (Plumbing and drainage—Water services), section 16
- 2 testing or commissioning of a sanitary plumbing or drainage installation in accordance with AS/NZS 3500.2:2003 (Plumbing and drainage—Sanitary plumbing and drainage), section 13
- 3 testing or commissioning of a heated water service in accordance with AS/NZS 3500.4:2003 (Plumbing and drainage—Heated water services), section 11

**Part 2 Complying with alternative
solutions under PCA**

- 4 testing or commissioning of a cold water service to ensure the installation of the cold water service complies with the performance requirements of PCA, part B1 (Cold water services)
- 5 testing or commissioning of a heated water service to ensure—

Schedule 4

- (a) the installation of the heated water service complies with the performance requirements of PCA, part B2 (Heated water services); and
 - (b) the hot water delivery temperatures comply with this regulation
- 6 testing or commissioning of a sanitary plumbing or drainage installation to ensure the sanitary plumbing or drainage complies with the performance requirements of PCA, part C1 (Sanitary plumbing systems) or C2 (Sanitary drainage systems)

Schedule 5 Local governments for remote areas

section 25(1)

Aramac Shire Council
Aurukun Shire Council
Balonne Shire Council
Barcaldine Shire Council
Barcoo Shire Council
Bauhinia Shire Council
Belyando Shire Council
Blackall Shire Council
Booringa Shire Council
Boulia Shire Council
Bowen Shire Council
Bulloo Shire Council
Bungil Shire Council
Burke Shire Council
Carpentaria Shire Council
Cloncurry Shire Council
Cook Shire Council
Croydon Shire Council
Dalrymple Shire Council
Diamantina Shire Council
Emerald Shire Council
Etheridge Shire Council
Flinders Shire Council

Ilfracombe Shire Council
Isisford Shire Council
Jericho Shire Council
Longreach Shire Council
Mareeba Shire Council
McKinlay Shire Council
Mornington Shire Council
Mount Isa City Council
Murweh Shire Council
Paroo Shire Council
Peak Downs Shire Council
Quilpie Shire Council
Richmond Shire Council
Tambo Shire Council
Taroom Shire Council
Torres Shire Council
Warroo Shire Council
Winton Shire Council

Schedule 6 Dictionary

section 4(1)

48 hours, for part 3, division 3, see section 17.

AHD means the Australian height datum adopted by the National Mapping Council of Australia for referencing a level or height back to a standard base level.

air cooling equipment see glossary.

air gap see glossary.

apparatus—

- (a) for sanitary plumbing, sanitary drainage and on-site sewerage facilities—
 - (i) includes an arrestor, cistern, pump, siphon or valve; but
 - (ii) does not include an appliance, fitting, fixture or straight pipe; or
- (b) for water plumbing—
 - (i) includes a backflow prevention device, cistern, pump, domestic water filter, water meter, siphon, tap, valve, water heater or water softener; but
 - (ii) does not include an appliance, fitting or straight pipe.

appliance see glossary.

applied provisions see section 5(1).

arrestor see glossary.

AS/NZS means a joint Standards Australia and Standards New Zealand standard.

backfill means fill.

basement see glossary.

BCA means the Building Code of Australia.

bedpan washer see glossary.

bend see glossary.

body of water means groundwater or a creek, lake, lagoon, marsh, river, stream, swamp or permanent or intermittent watercourse.

certified item means a plumbing or drainage item that has plumbing code authorisation and certification before installation or use.

chamber see glossary.

channel see glossary.

cistern see glossary.

combined sanitary drain means a sanitary drain for discharges from 2 or more adjacent premises.

commission, plumbing or drainage—

- (a) means check the operation of a potable cold water service or hot water service associated with the plumbing or drainage to confirm the correct functioning of apparatus installed in the water service; and
- (b) includes check the delivery temperature of hot water at a specified outlet does not exceed the maximum temperature allowed for the hot water.

community titles scheme see the *Body Corporate and Community Management Act 1997*, section 10.

competent person, for plumbing or drainage or on-site sewerage work, means a person who—

- (a) in the opinion of the local government, is competent to practise in the aspect of design of plumbing or drainage or an on-site sewerage facility, including, for example, giving and certifying plans for plumbing or drainage work or on-site sewerage work; and
- (b) if required under the Act or another Act to be registered or licensed to practise in the aspect, is registered or licensed.

compliance report see section 22(3).

component—

- 1 A *component*, of sanitary drainage or sanitary plumbing, means apparatus, or an appliance, fitting, fixture or straight pipe, forming part of the sanitary drainage or sanitary plumbing.
- 2 A *component*, of water plumbing, means apparatus, or an appliance, fitting or straight pipe, forming part of the water plumbing.

condensate see glossary.

connection point—

- 1 A *connection point*, for a service provider's water supply system, means the point for the connection to the service provider's water supply system of—
 - (a) a supply pipe or premises main for premises; or
 - (b) a premises group main for a premises group.
- 2 A *connection point*, for a service provider's sewerage system, means the point for the connection to the service provider's sewerage system of—
 - (a) a sanitary drain or premises sewer for premises; or
 - (b) a premises group sewer for a premises group.

cover see glossary.

disconnecter gully see glossary.

double check valve see glossary.

effluent see glossary.

emergency work means plumbing or drainage work that must, because of a failure in plumbing or drainage, be performed to stop a continuing risk to health and safety or damage to property.

evaporative air conditioner see glossary.

fall see glossary.

fill see glossary.

filter see glossary.

fire service see glossary.

fitting see glossary.

fixture see glossary.

fixture trap see glossary.

float valve see glossary.

floor type urinal means a urinal that has a channel at or near floor level.

floor waste gully see glossary.

glossary see section 5(2).

grade see glossary.

grease arrester means an arrester intended only, or at least primarily, for grease.

ground level see glossary.

impervious material means material that—

- (a) water does not ordinarily penetrate; and
- (b) in the circumstances of its installation and use, is resistant to degradation caused by contact with sewage and trade waste.

inspection opening see glossary.

installation see glossary.

integral trap see glossary.

invert see glossary.

invert level see glossary.

isolating valve see glossary.

joint see glossary.

jumper valve see glossary.

local planning instrument see the *Integrated Planning Act 1997*, schedule 10.

notifiable minor work means the work listed in schedule 2, part 1.

on-site sewerage application area, for an on-site sewage treatment plant on premises, means a part of the premises, commonly called a 'land application area', to which effluent from the on-site sewage treatment plant is disposed.

other minor work means the work listed in schedule 2, part 2, to the extent it is not notifiable minor work.

outlet see glossary.

PCA means the Plumbing Code of Australia.

pipe see glossary.

plug see glossary.

Plumbing Code of Australia means the document in force from time to time called 'Plumbing Code of Australia', produced for all State governments by the National Plumbing Regulators Forum.

plumbing or drainage item means any apparatus, fitting, fixture or pipe used for plumbing or drainage.

premises group means the land comprised in 2 or more premises, all the owners of which have mutual rights and obligations under the *Body Corporate and Community Management Act 1997* or the *Building Units and Group Titles Act 1980* for their respective ownerships, and includes the common property forming part of—

- (a) if the premises are lots included in a community titles scheme under the *Body Corporate and Community Management Act 1997*—the scheme land under that Act for the scheme; or
- (b) if the premises are lots under the *Building Units and Group Titles Act 1980*—the parcel of which the premises form part.

premises group main see section 34(3)(a).

premises group sewer see section 35(3).

premises main see section 34(2)(a).

premises sewer see section 35(2).

pressure type vacuum breaker see glossary.

property service means a short length of pipe installed for connecting premises to a water main, whether or not built to the standard of a water main.

pump see glossary.

QPW code see section 4A(1).

Queensland Plumbing and Wastewater Code see section 4A(1).

reduced pressure zone device see glossary.

registered air gap means an air gap complying with the requirements for a registered air gap in AS/NZS 3500.1:2003.

registered break tank means a break tank complying with the requirements for a registered break tank in AS/NZS 3500.1:2003.

remote area see section 25.

replacing, of a plumbing or drainage item, means removing the item from a place and installing a new item of a similar type in the same place.

responsible person, for part 3, division 3, see section 17.

riser see glossary.

sanitary plumbing means an apparatus, fitting, fixture or pipe, above ground level, that carries sewage to a sanitary drain.

service provider has the meaning given under the *Water Act 2000*.

sink see glossary.

siphon see glossary.

slab urinal see glossary.

soil pipe see glossary.

soil stack see glossary.

stack see glossary.

supply pipe means a pipe for supplying and conveying water within premises.

tank see glossary.

tap see glossary.

test see glossary.

testable backflow prevention device means any of the following—

- (a) a double check valve;
- (b) a pressure type vacuum breaker;
- (c) a reduced pressure zone device;
- (d) a registered air gap;
- (e) a registered break tank.

testable single check valve means a device to prevent backflow caused by backpressure that has 1 force loaded non-return valve and incorporates specific test points for in-service testing.

trade waste means water-borne waste from business, trade or manufacturing premises, other than—

- (a) waste that is a prohibited substance; and
- (b) human waste; and
- (c) stormwater.

trap see glossary.

trap water seal see glossary.

upstream vent see glossary.

urinal see glossary.

valve see glossary.

vent see glossary.

vent pipe see glossary.

waste pipe see glossary.

waste water see glossary.

water closet pan see glossary.

water closet (WC) cistern see glossary.

water heater see glossary.

water main see glossary.

water plumbing means an apparatus, fittings, or pipe for carrying water within premises.

water supply system means infrastructure used to reticulate and supply water, whether or not used also to store or treat water, and consisting of water mains, property services and some or all of the following—

- (a) valves;
- (b) engines;
- (c) pumps;
- (d) structures;
- (e) machinery;
- (f) works not mentioned in paragraphs (a) to (e).

wrapping see glossary.

Endnotes

1 Index to endnotes

	Page
2 Date to which amendments incorporated	73
3 Key	73
4 Table of reprints	74
5 List of legislation	74
6 List of annotations	75

2 Date to which amendments incorporated

This is the reprint date mentioned in the Reprints Act 1992, section 5(c). Accordingly, this reprint includes all amendments that commenced operation on or before 1 March 2009. Future amendments of the Standard Plumbing and Drainage Regulation 2003 may be made in accordance with this reprint under the Reprints Act 1992, section 49.

3 Key

Key to abbreviations in list of legislation and annotations

Key	Explanation	Key	Explanation
AIA	= Acts Interpretation Act 1954	(prev)	= previously
amd	= amended	proc	= proclamation
amdt	= amendment	prov	= provision
ch	= chapter	pt	= part
def	= definition	pubd	= published
div	= division	R[X]	= Reprint No. [X]
exp	= expires/expired	RA	= Reprints Act 1992
gaz	= gazette	reloc	= relocated
hdg	= heading	renum	= renumbered
ins	= inserted	rep	= repealed
lap	= lapsed	(retro)	= retrospectively
notfd	= notified	rv	= revised edition
num	= numbered	s	= section
o in c	= order in council	sch	= schedule
om	= omitted	sdiv	= subdivision
orig	= original	SIA	= Statutory Instruments Act 1992
p	= page	SIR	= Statutory Instruments Regulation 2002
para	= paragraph	SL	= subordinate legislation
prec	= preceding	sub	= substituted
pres	= present	unnum	= unnumbered
prev	= previous		

4 Table of reprints

Reprints are issued for both future and past effective dates. For the most up-to-date table of reprints, see the reprint with the latest effective date.

If a reprint number includes a letter of the alphabet, the reprint was released in unauthorised, electronic form only.

Reprint No.	Amendments included	Effective	Notes
1	none	1 November 2003	
1A	2005 SL No. 323	16 December 2005	
1B	2005 SL No. 323	1 March 2006	
1C	2007 SL No. 328	1 January 2008	
1D	2008 SL No. 375	14 November 2008	
1E	2009 SL No. 17	1 March 2009	R1E withdrawn, see R2
2	—	1 March 2009	

5 List of legislation

Standard Plumbing and Drainage Regulation 2003 SL No. 265

made by the Governor in Council on 30 October 2003

notfd gaz 31 October 2003 pp 691–4

ss 1–2 commenced on date of notification

remaining provisions commenced 1 November 2003 (see s 2)

exp 1 September 2014 (see SIA s 54)

Note—The expiry date may have changed since this reprint was published. See the latest reprint of the SIR for any change.

amending legislation—

Plumbing and Drainage Legislation Amendment Regulation (No. 1) 2005 SL No. 323 pts 1, 3

notfd gaz 16 December 2005 pp 1490–6

ss 1–2, pt 3 hdg, 7, 10, 12–14, 17–19, 32, 41, 44, 45(1), (to the extent it om def in sch 6 “part 1.2”, “part 4.2”), 45(2), (to the extent it ins def in sch 6 “AS/NZS”, “PCA”, “Plumbing Code of Australia”), 45(3) commenced on date of notification (see s 2(b)–(e))

remaining provisions commenced 1 March 2006 (see s 2)

Plumbing and Drainage and Other Legislation Amendment Regulation (No. 1) 2007 SL No. 328 pts 1–2

notfd gaz 14 December 2007 pp 2131–5

ss 1–2 commenced on date of notification

remaining provisions commenced 1 January 2008 (see s 2)

Building and Other Legislation Amendment Regulation (No. 2) 2008 SL No. 375 pts 1, 3

notfd gaz 14 November 2008 pp 1346–7

commenced on date of notification

Building and Other Legislation Amendment Regulation (No. 1) 2009 SL No. 17 pts 1, 4

notfd gaz 20 February 2009 pp 852–3
 ss 1–2 commenced on date of notification
 remaining provisions commenced 1 March 2009 (see s 2)

6 List of annotations**Status**

s 3 amd 2005 SL No. 323 s 8

What is the “Queensland Plumbing and Wastewater Code” (or “QPW code”)

s 4A ins 2005 SL No. 323 s 9

What are the “applied provisions” and “glossary”

s 5 sub 2005 SL No. 323 s 10

PART 1A—PRESCRIBED MATTERS FOR ACT

pt hdg ins 2005 SL No. 323 s 11

Criteria local government must consider in declaring area to be suitable for greywater use

s 6A ins 2005 SL No. 323 s 11
 om 2007 SL No. 328 s 4

Criteria for deciding application for compliance permit for greywater use facility in a sewered area

6B ins 2005 SL No. 323 s 11
 amd 2007 SL No. 328 s 5

Minor work—Act, sch, definition “minor work”

s 7 amd 2005 SL No. 323 s 12

PART 2—COMPLIANCE WITH PARTICULAR CODES AND STANDARDS

pt hdg sub 2005 SL No. 323 s 13

Compliance with Plumbing Code of Australia

s 8A ins 2005 SL No. 323 s 14

Compliance with QPW code

s 8B ins 2005 SL No. 323 s 15

Relationship between PCA and QPW code

s 8C ins 2005 SL No. 323 s 15

Regulated work and on-site sewerage work

prov hdg amd 2005 SL No. 323 s 16(1)

s 9 amd 2005 SL No. 323 s 16(2)

Minor work and unregulated work

s 10 amd 2005 SL No. 323 s 17

Endnotes

Limited application of AS/NZS 3500.1:2003

prov hdg amd 2005 SL No. 323 s 18(1)

s 11 amd 2005 SL No. 323 s 18(2)

Limited application of AS/NZS 3500.4:2003

prov hdg amd 2005 SL No. 323 s 19(1)

s 12 amd 2005 SL No. 323 s 19(2)–(3)

Application of pt 3

s 13 amd 2005 SL No. 323 s 20

General requirements for plans the subject of a compliance request

prov hdg sub 2005 SL No. 323 s 21(1)

s 14 amd 2005 SL No. 323 s 21

Additional requirements for plans for regulated work

s 14A ins 2005 SL No. 323 s 22

amd 2007 SL No. 328 s 6

Additional requirements for plans for greywater use facilities in a sewered area

s 14B ins 2005 SL No. 323 s 22

amd 2007 SL No. 328 s 7

Additional requirements for plans for greywater use facilities not in a sewered area

s 14C ins 2005 SL No. 323 s 22

amd 2007 SL No. 328 s 8

Additional requirements for plans for on-site sewerage facilities

s 14D ins 2005 SL No. 323 s 22

Certificates for plan given by competent person

s 15 amd 2005 SL No. 323 s 23

Requirement for additional documents for particular plans

prov hdg sub 2005 SL No. 323 s 24(1)

s 16 amd 2005 SL No. 323 s 24(2)–(5)

Division 3—Assessing plumbing and drainage work or on-site sewerage work

div hdg amd 2005 SL No. 323 s 25

Definitions for div 3

s 17 def “**48 hours**” amd 2005 SL No. 323 s 26

def “**responsible person**” sub 2005 SL No. 323 s 26

Request for compliance assessment of regulated work or on-site sewerage work

prov hdg amd 2005 SL No. 323 s 27(1)

s 18 amd 2005 SL No. 323 s 27(2)–(4)

Stages for assessment of regulated work

prov hdg amd 2005 SL No. 323 s 28(1)

s 19 amd 2005 SL No. 323 s 28(2)–(5); 2007 SL No. 328 s 9

Stages for assessment of on-site sewerage work

s 19A ins 2005 SL No. 323 s 29

Obligations of responsible person for on-site sewerage work

s 19B ins 2005 SL No. 323 s 29

Assessment of stages of work by local government

s 20 amd 2005 SL No. 323 s 30

Covering plumbing and drainage or on-site sewerage facility

prov hdg amd 2005 SL No. 323 s 31(1)

s 21 amd 2005 SL No. 323 s 31(2)–(4)

Testing and commissioning plumbing and drainage

s 22 amd 2005 SL No. 323 s 32

General requirements for plans for assessed work

s 23 sub 2005 SL No. 323 s 33

Additional requirements for plans for assessed regulated work

s 23A ins 2005 SL No. 323 s 33

amd 2007 SL No. 328 s 10

Additional requirements for plans for assessed greywater use facilities in a sewerage area

s 23B ins 2005 SL No. 323 s 33

amd 2007 SL No. 328 s 11

Additional requirements for plans for assessed greywater use facilities not in a sewerage area

s 23C ins 2005 SL No. 323 s 33

amd 2007 SL No. 328 s 12

Additional requirements for plans for assessed on-site sewerage work

s 23D ins 2005 SL No. 323 s 33

Division 4—Assessing regulated work or on-site sewerage work in remote areas

div hdg amd 2005 SL No. 323 s 34

Application of div 4

s 24 amd 2005 SL No. 323 s 35

Meaning of “remote area”

s 25 amd 2005 SL No. 323 s 36

Request for compliance assessment of regulated work or on-site sewerage work

prov hdg amd 2005 SL No. 323 s 37(1)

s 26 amd 2005 SL No. 323 s 37(2)

Plan of completed work

s 28 amd 2005 SL No. 323 s 38

Non-certified items allowed for fire service

s 31 amd 2008 SL No. 375 s 5

Testable backflow prevention devices

s 38 amd 2005 SL No. 323 s 39

Endnotes

PART 7—MISCELLANEOUS PROVISIONS

pt hdg prev pt 7 hdg om R1 (see RA s 7(1)(k))
pres pt 7 hdg ins 2005 SL No. 323 s 40

Maintenance of existing combined sanitary drains

s 54 ins 2005 SL No. 323 s 40

Notice to water service provider about installation of meters

s 54A ins 2007 SL No. 328 s 13

Evidentiary aids

s 55 prev s 55 om R1 (see RA s 40)
pres s 55 ins 2005 SL No. 323 s 40

**PART 8—TRANSITIONAL PROVISIONS FOR PLUMBING AND DRAINAGE
LEGISLATION AMENDMENT REGULATION (No. 1) 2005**

pt hdg ins 2005 SL No. 323 s 40

Definition for pt 8

s 56 prev s 56 om R1 (see RA s 40)
pres s 56 ins 2005 SL No. 323 s 40

Existing requests for compliance assessment of plans for regulated work

s 57 prev s 57 om R1 (see RA s 40)
pres s 57 ins 2005 SL No. 323 s 40

Existing requests for compliance assessment of regulated work

s 58 prev s 58 om R1 (see RA s 40)
pres s 58 ins 2005 SL No. 323 s 40

Plumbing and drainage work

s 59 ins 2005 SL No. 323 s 40

SCHEDULE 1—APPLIED PROVISIONS

sub 2005 SL No. 323 s 41

SCHEDULE 1A—REFERENCES TO PARTS OF QPW CODE

ins 2005 2005 SL No. 323 s 42
sub 2007 SL No. 328 s 14; 2008 SL No. 375 s 6; 2009 SL No. 17 s 9

SCHEDULE 2—MINOR WORK

amd 2005 SL No. 323 s 43

**SCHEDULE 4—WORK FOR WHICH APPROVED PERSON MAY GIVE
COMPLIANCE REPORTS**

sub 2005 SL No. 323 s 44

SCHEDULE 6—DICTIONARY

def “**apparatus**” amd 2007 SL No. 328 s 15(2)
def “**AS/NZS**” ins 2005 SL No. 323 s 45(2)
def “**body of water**” ins 2005 SL No. 323 s 45(2)
def “**Building Code of Australia**” om 2005 SL No. 323 s 45(1)
def “**certified item**” sub 2005 SL No. 323 s 45(1)–(2)
def “**combined sanitary drain**” ins 2005 SL No. 323 s 45(2)

- def **“competent person”** sub 2005 SL No. 323 s 45(1)–(2)
- def **“MAP”** om 2005 SL No. 323 s 45(1)
- def **“MAP certification”** om 2005 SL No. 323 s 45(1)
- def **“meter”** om 2007 SL No. 328 s 15(1)
- def **“on-site sewerage application area”** ins 2005 SL No. 323 s 45(2)
- def **“part 1.2”** om 2005 SL No. 323 s 45(1)
- def **“part 4.2”** om 2005 SL No. 323 s 45(1)
- def **“PCA”** ins 2005 SL No. 323 s 45(2)
- def **“Plumbing Code of Australia”** ins 2005 SL No. 323 s 45(2)
- def **“QPW code”** ins 2005 SL No. 323 s 45(2)
- def **“Queensland Plumbing and Wastewater Code”** ins 2005 SL No. 323 s 45(2)
- def **“registered air gap”** amd 2005 SL No. 323 s 45(3)
- def **“registered break tank”** amd 2005 SL No. 323 s 45(3)
- def **“sanitary drainage”** om 2005 SL No. 323 s 45(1)
- def **“sewage”** om 2005 SL No. 323 s 45(1)

© State of Queensland 2009